

Certificate



Registration No.: PV 60099571

Page 1

Report No.: 21221521.002

License Holder:

Vikram Solar Private Limited

Tobacco House, 1 Old Court House Corner
Kolkata 700001
India

Product:

PV Modules

Type:

with 6" poly-crystalline cells:

ELDORA VSP.60.AAA.03 with 228 - 279 Wp, 60 cells
ELDORA VSP.54.AAA.03 with 205 - 250 Wp, 54 cells
ELDORA VSP.48.AAA.03 with 182 - 223 Wp, 48 cells
ELDORA VSP.36.AAA.03 with 137 - 168 Wp, 36 cells

ELDORA VSPB.60.AAA.03 with 228 - 279 Wp, 60 cells
ELDORA VSPB.54.AAA.03 with 205 - 250 Wp, 54 cells
ELDORA VSPB.48.AAA.03 with 182 - 223 Wp, 48 cells
ELDORA VSPB.36.AAA.03 with 137 - 168 Wp, 36 cells

ELDORA VSPBB.60.AAA.03 with 228 - 279 Wp, 60 cells
ELDORA VSPBB.54.AAA.03 with 205 - 250 Wp, 54 cells
ELDORA VSPBB.48.AAA.03 with 182 - 223 Wp, 48 cells
ELDORA VSPBB.36.AAA.03 with 137 - 168 Wp, 36 cells

Manufacturing plant:

Vikram Solar Private Limited
Special Economic Zone, Sector 2, Falta
24 Parganas (South)
West Bengal - 743504
India

Basis:

IEC 61701:2011
EN 61701:2012
"Salt mist corrosion testing of
photovoltaic (PV) modules"

Factory Inspection
To document the consistent quality of
the product factory inspections are
performed periodically



www.tuv.com
ID 0000042921

Remarks:

- Valid in conjunction with TÜV Rheinland certificate acc. to IEC EN 61215 and **only** for the material combination as listed in the above mentioned test report.
- Test performed with **severity 6** of 6.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval. Accordingly the repetition of the tests that are basis of this certificate may be required.

The certificate is valid until 27 January 2020.

Certification body



Dipl.-Ing. M. Adrian

Cologne, 30 January 2015